

# EU DECLARATION OF CONFORMITY

## No. 1A-EU-06/23-02

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**  
 Havlíčkova 432  
 280 02 Kolín  
 Czech Republic  
 IČ: 61672971  
 DIČ: CZ61672971

declare under our sole responsibility that

product **Elektroinstalation fire resistant boxes**

type: **KSK 80, KSK 100, KSK 125, KSK 175**  
 variants: **Orange**

manufacturer: **KOPOS KOLÍN a.s. Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: Boxes and covers used for electric accessories for house and other similar fixed electrical installations. Intended for installation in environments that require IP66 protection. Boxes have integrated knockouts for mounting on base. Perfect sealing of cables and pipes. Clow wire test satisfies: the membrane at 850 ° C, the lid of the box at 850 ° C and the box body at 650 ° C. The needle burner test was conducted in accordance with ČSN EN 60695-11-5. Temperature resistance boxes during installation is from -25 ° C to + 60 ° C.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:21 including amendments	Test Report No. 222525-01/01 of 28.11.2022 Test Report corrected on 06.01.2023	
	Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)	Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
		ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 702425-01/01 of 24.11.2017	
		ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)	Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
		ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)		

		ČSN EN 60670-1:05+A1:13 čl. 15.3 including amendments	Test Report No. 403994-01/01 of 26.11.2014  Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	Impact test for boxes and enclosures:  Cover KSK 100 Cover KSK 80
--	--	---	---	--

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.  
Conformity assessment module: **MODUL A: Internal production control**

**Technical documentation of products:**

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents


KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 and according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.

Place of issue: Kolín, Czech Republic

Date of issue: 28.02.2023

  
Ing. Jana Dějmková  
quality director

KOPOS KOLÍN a.s.   
Havlíčková 432, 280 02 Kolín  
IČ: 616 72 971 DIČ: CZ61672971  
tel: 321 730 111 [www.kopos.cz](http://www.kopos.cz)